1512 S BATAVIA AVENUE GENEVA, IL 60134 An MALION Technical Center

RIVERBANK.ALIONSCIENCE.COM FOUNDED 1918 BY WALLACE CLEMENT SABINE

GENEVA, IL 60134 630-232-0104

Test Report

Sound Absorption RAL<sup>TM</sup>-A20-302

SPONSOR: FabriTRAK Systems Inc.

Mount Laurel, NJ

CONDUCTED: 2020-07-14 Page 1 of 8

ON: 1 in. Terra Core Poly Hi-Impact Infill (100% Polyester Infill) (Type A mounting)

#### **TEST METHODOLOGY**

Riverbank Acoustical Laboratories<sup>TM</sup> is accredited by the U.S. Department of Commerce, National Institute of Standards and Technology (NIST) under the National Voluntary Laboratory Accreditation Program (NVLAP) as an ISO 17025:2017 Laboratory (NVLAP Lab Code: 100227-0) and for this test procedure. The test reported in this document conformed explicitly with ASTM C423-17: "Standard Test Method for Sound Absorption and Sound Absorption Coefficients by the Reverberation Room Method." The specimen mounting was performed according to ASTM E795-16: "Standard Practices for Mounting Test Specimens During Sound Absorption Tests." A description of the measurement procedure and room specifications are available upon request. The results presented in this report apply to the sample as received from the test sponsor.

#### INFORMATION PROVIDED BY SPONSOR

The test specimen was designated by the sponsor as 1 in. Terra Core Poly Hi-Impact Infill (100% Polyester Infill) (Type A mounting). The following nominal product information was provided by the sponsor prior to testing. The accuracy of such sponsor-provided information can affect the validity of the test results.

#### **Product Under Test**

Trade Name: Terra Core Poly Hi-Impact Infill

Material: 100 % polyester infill

Thickness: 25.4 mm (1 in.)

Manufacturer: FabriTRAK Systems Inc.

## SPECIMEN MEASUREMENTS & TEST CONDITIONS

Through a full external visual inspection performed on the test specimen, Riverbank personnel verified the following information:

#### **Test Specimen**

Material: Semirigid felt panels

Dimensions: 4 @ 1219.2 mm (48 in.) x 1219.2 mm (48 in.)

2 @ 304.8 mm (12 in.) x 1219.2 mm (48 in.)

Thickness: 23.22 mm (0.914 in.) Overall Weight: 10.21 kg (22.5 lbs)

Density:  $65.72 \text{ kg/m}^3 (4.10 \text{ lbs/ft}^3)$ 



® RIVERBANK ACOUSTICAL LABORATORIES IS ACCREDITED BY NVLAP (LAB CODE 100227-0) FOR ACOUSTICAL TESTING SERVICES IN ACCORDANCE WITH ISO/IEC 17025:2017 AND FOR THIS PROCEDURE. THIS REPORT MUST NOT BE USED BY THE CLIENT TO CLAIM PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY RAL, NVLAP, NIST, OR ANY AGENCY OF THE U.S. GOVERNMENT. THIS REPORT SHALL NOT BE MODIFIED WITHOUT THE WRITTEN APPROVAL OF RAL. THE RESULTS REPORTED APPLY ONLY TO THE

SPECIFIC SAMPLE SUBMITTED FOR TESTING; RAL ASSUMES NO RESPONSIBILITY FOR THE PERFORMANCE OF ANY OTHER SAMPLE.

**1512 S BATAVIA AVENUE** GENEVA, IL 60134 630-232-0104

An MALION Technical Center

RIVERBANK.ALIONSCIENCE.COM FOUNDED 1918 BY WALLACE CLEMENT SABINE

Test Report

RAL<sup>TM</sup>-A20-302 Page 2 of 8

FabriTRAK Systems Inc.

2020-07-14

**Overall Specimen Properties** 

Size: 2.74 m (108.0 in) wide by 2.44 m (96.0 in) long

Thickness: 0.02 m (0.914 in) Weight: 10.21 kg (22.5 lbs)

Mass per Unit Area:  $1.53 \text{ kg/m}^2 (0.31 \text{ lbs/ft}^2)$ 

Calculation Area: 6.689 m<sup>2</sup> (72 ft<sup>2</sup>)

**Test Environment** 

Room Volume: 291.98 m<sup>3</sup>

Temperature:  $22.6 \,^{\circ}\text{C} \pm 0.1 \,^{\circ}\text{C}$  (Requirement:  $\geq 10 \,^{\circ}\text{C}$  and  $\leq 5 \,^{\circ}\text{C}$  change) Relative Humidity:  $58.6 \% \pm 0.0 \%$  (Requirement:  $\geq 40 \%$  and  $\leq 5 \%$  change)

Barometric Pressure: 98.7 kPa (Requirement not defined)

#### MOUNTING METHOD

Type A Mounting: The test specimen was laid directly against the test surface. Perimeter edges were sealed with metal framing.

An MALION Technical Center

1512 S BATAVIA AVENUE GENEVA, IL 60134 630-232-0104

Test Report

RIVERBANK.ALIONSCIENCE.COM FOUNDED 1918 BY WALLACE CLEMENT SABINE

> RAL<sup>TM</sup>-A20-302 Page 3 of 8

**FabriTRAK Systems Inc.** 2020-07-14




Figure 1 – Specimen mounted in test chamber



Figure 2 – Detail of specimen material



RIVERBANK ACOUSTICAL LABORATORIES IS ACCREDITED BY NVLAP (LAB CODE 100227-0) FOR ACOUSTICAL TESTING SERVICES IN ACCORDANCE WITH ISO/IEC 17025:2017 AND FOR THIS PROCEDURE. THIS REPORT MUST NOT BE USED BY THE CLIENT TO CLAIM PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY RAL, NVLAP, NIST, OR ANY AGENCY OF THE U.S. GOVERNMENT. THIS REPORT SHALL NOT BE MODIFIED WITHOUT THE WRITTEN APPROVAL OF RAL. THE RESULTS REPORTED APPLY ONLY TO THE SPECIFIC SAMPLE SUBMITTED FOR TESTING; RAL ASSUMES NO RESPONSIBILITY FOR THE PERFORMANCE OF ANY OTHER SAMPLE.

An MALION Technical Center

**1512 S BATAVIA AVENUE** GENEVA, IL 60134 630-232-0104

Test Report

RIVERBANK.ALIONSCIENCE.COM FOUNDED 1918 BY WALLACE CLEMENT SABINE

> RAL<sup>TM</sup>-A20-302 Page 4 of 8


FabriTRAK Systems Inc. 2020-07-14

#### TEST RESULTS

Specimen total absorption and absorption coefficient are tabulated at the eighteen standard frequencies. A graphic presentation of the data and additional information appear on the following pages.

1/3 Octave Center			
Frequency	<b>Total Absorption</b>	<b>Total Absorption</b>	Absorption
(Hz)	$(m^2)$	(Sabins)	Coefficient
100	0.36	3.89	0.05
** 125			
	0.87	9.38	0.13
160	1.04	11.24	0.16
200	1.28	13.74	0.19
** 250	1.75	18.85	0.26
315	2.38	25.66	0.36
400	2.90	31.26	0.43
** 500	3.66	39.43	0.55
630	4.34	46.66	0.65
030	4.34	40.00	0.03
800	4.78	51.40	0.71
** 1000	5.15	55.46	0.77
1250	5.35	57.56	0.80
1600	5.59	60.13	0.84
** 2000	5.71	61.48	0.85
2500	6.04	64.98	0.90
2300	0.04	04.70	0.90
3150	6.14	66.07	0.92
** 4000	6.21	66.83	0.93
5000	6.45	69.42	0.96

SAA = 0.61NRC = 0.60



An MALION Technical Center

Test Report

1512 S BATAVIA AVENUE GENEVA, IL 60134 630-232-0104

RIVERBANK.ALIONSCIENCE.COM FOUNDED 1918 BY WALLACE CLEMENT SABINE

> RAL<sup>TM</sup>-A20-302 Page 5 of 8

**FabriTRAK Systems Inc.** 2020-07-14

#### TEST RESULTS (continued)

The sound absorption average (SAA) is defined in ASTM C423-17 Section 3.1.1 as the arithmetic average of the sound absorption coefficients of a material for the twelve one-third octave bands from 200 Hz through 2500 Hz, inclusive, rounded to the nearest integer multiple of 0.01.

The noise reduction coefficient (NRC) is defined from previous versions of ASTM C423 as the arithmetic average of the sound absorption coefficients at 250 Hz, 500 Hz, 1000 Hz, and 2000 Hz, rounded to the nearest integer multiple of 0.05.

Tested by // / Auc. Marc Sciaky

Senior Experimentalist

Report by\_

Malcolm Kelly

Acoustical Test Engineer

Approved b

Eric P. Wolfram

Laboratory Manager

1512 S BATAVIA AVENUE GENEVA, IL 60134 630-232-0104 An MALION Technical Center

Test Report


RIVERBANK.ALIONSCIENCE.COM FOUNDED 1918 BY WALLACE CLEMENT SABINE

> RAL<sup>TM</sup>-A20-302 Page 6 of 8

**FabriTRAK Systems Inc.** 2020-07-14

## **SOUND ABSORPTION REPORT**

I in. Terra Core Poly Hi-Impact Infill (100% Polyester Infill) (Type A mounting)



SAA = 0.61NRC = 0.60



® RIVERBANK ACOUSTICAL LABORATORIES IS ACCREDITED BY NVLAP (LAB CODE 100227-0) FOR ACOUSTICAL TESTING SERVICES IN ACCORDANCE WITH ISO/IEC 17025:2017 AND FOR THIS PROCEDURE. THIS REPORT MUST NOT BE USED BY THE CLIENT TO CLAIM PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY RAL, NVLAP, NIST, OR ANY AGENCY OF THE U.S. GOVERNMENT.

THIS REPORT SHALL NOT BE MODIFIED WITHOUT THE WRITTEN APPROVAL OF RAL. THE RESULTS REPORTED APPLY ONLY TO THE SPECIFIC SAMPLE SUBMITTED FOR TESTING; RAL ASSUMES NO RESPONSIBILITY FOR THE PERFORMANCE OF ANY OTHER SAMPLE.

1512 S BATAVIA AVENUE GENEVA, IL 60134 630-232-0104

# An MALION Technical Center

Test Report

RIVERBANK.ALIONSCIENCE.COM FOUNDED 1918 BY WALLACE CLEMENT SABINE

> RAL<sup>TM</sup>-A20-302 Page 7 of 8

FabriTRAK Systems Inc. 2020-07-14

#### **APPENDIX A: Extended Frequency Range Data**

1/3 Octave Rand

Specimen: 1 in. Terra Core Poly Hi-Impact Infill (100% Polyester Infill) (Type A mounting) (See Full Report)

The following non-accredited data were obtained in accordance with ASTM C423-17, but extend beyond the defined frequency range of 100Hz to 5,000Hz. These unofficial results are representative of the RAL test environment only and intended for research & comparison purposes.

1/3 Octave Band	777 ( ) A ) ( )	43
Center Frequency	Total Absorption	Absorption
(Hz)	(Sabins)	Coefficient
31.5	-1.43	-0.02
40	-2.67	-0.04
50	4.28	0.06
63	7.46	0.10
80	-0.26	0.00
100	3.89	0.05
125	9.38	0.13
160	11.24	0.16
200	13.74	0.19
250	18.85	0.26
315	25.66	0.36
400	31.26	0.43
500	39.43	0.55
630	46.66	0.65
800	51.40	0.71
1000	55.46	0.77
1250	57.56	0.80
1600	60.13	0.84
2000	61.48	0.85
2500	64.98	0.90
3150	66.07	0.92
4000	66.83	0.93
5000	69.42	0.96
6300	69.36	0.96
8000	71.73	1.00
10000	76.67	1.06
12500	75.63	1.05



® RIVERBANK ACOUSTICAL LABORATORIES IS ACCREDITED BY NVLAP (LAB CODE 100227-0) FOR ACOUSTICAL TESTING SERVICES IN ACCORDANCE WITH ISO/IEC 17025:2017 AND FOR THIS PROCEDURE. THIS REPORT MUST NOT BE USED BY THE CLIENT TO CLAIM PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY RAL, NVLAP, NIST, OR ANY AGENCY OF THE U.S. GOVERNMENT. THIS REPORT SHALL NOT BE MODIFIED WITHOUT THE WRITTEN APPROVAL OF RAL. THE RESULTS REPORTED APPLY ONLY TO THE

An MALION Technical Center

1512 S BATAVIA AVENUE GENEVA, IL 60134 630-232-0104

Test Report

RIVERBANK.ALIONSCIENCE.COM FOUNDED 1918 BY WALLACE CLEMENT SABINE

FabriTRAK Systems Inc. 2020-07-14

RAL<sup>TM</sup>-A20-302 Page 8 of 8

## **APPENDIX B: Instruments of Traceability**

Specimen: 1 in. Terra Core Poly Hi-Impact Infill (100% Polyester Infill) (Type A mounting) (See Full Report)

		Serial	Date of	Calibration
<b>Description</b>	<b>Model</b>	<u>Number</u>	<b>Certification</b>	<u>Due</u>
System 1	Type 3160-A-042	3160- 106968	2020-06-26	2021-06-26
Bruel & Kjaer Mic And Preamp A	Type 4943-B-001	2311428	2019-09-27	2020-09-27
Bruel & Kjaer Pistonphone	Type 4228	2781248	2019-08-09	2020-08-09
Omega Digital Temp., Humid. And Pressure Recorder	OM-CP- PRHTemp2000	P97844	2020-02-18	2021-02-18

## **APPENDIX C: Revisions to Original Test Report**

Specimen: 1 in. Terra Core Poly Hi-Impact Infill (100% Polyester Infill) (Type A mounting) (See Full Report)

<u>Date</u>	<b>Revision</b>
2020-07-20	Original report issued

**END** 

